

### Inorganic Contaminants

Year (Range)	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2000 2000	Barium	0.081	0.081	0.081	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
2003 2003	Fluoride	0.300	0.3	0.3	4	4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
2004 2004	Nitrate	0.090	0.09	0.09	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
2003 2003	Gross beta emitters	3.500	3.5	3.5	50	0	pCi/L	Decay of natural and man-made deposits.
2003 2003	Gross alpha	2.000	2	2	15	0	pCi/L	Erosion of natural deposits.

### Organic Contaminants

Year (Range)	Contaminant	Highest Average	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2002 2002	Xylenes	0.002	0.0016	0.0016	10	10	ppm	Discharge from petroleum factories; discharge from chemical factories.

### Maximum Residual Disinfectant Level NOT TESTED OR REPORTED

Systems must complete and submit disinfection data on the Disinfection Level Quarterly Operating Report (DLQOR). Failure to do so WILL result in violation(s).

### Disinfection Byproducts

Year (Range)	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2004 2004	Total Haloacetic Acids	1.100	1.1	1.1	60	ppb	Byproduct of drinking water disinfection.
2004 2004	Total Trihalomethanes	2.500	2.5	2.5	80	ppb	Byproduct of drinking water disinfection.

### Unregulated Contaminants

Year (Range)	Contaminant	Average Level	Minimum Level	Maximum Level	Unit of Measure	Source of Contaminant
2002 2002	Chloroform	1.300	1.3	1.3	ppb	Byproduct of drinking water disinfection.
2002 2002	Dibromochloromethane	1.600	1.6	1.6	ppb	Byproduct of drinking water disinfection.