

Lead and Copper

Year (Range)	Contaminant	The 90th Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Source of Contaminant
2002 2002	Lead	2.6000	1	15	ppb	Corrosion of household plumbing systems; erosion of natural deposits.
2002 2002	Copper	0.1690	0	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

Turbidity NOT REQUIRED

Total Coliform NOT DETECTED

Fecal Coliform NOT DETECTED

Secondary and Other Not Regulated Constituents

(No associated adverse health effects)

Year (Range)	Constituent	Average Level	Minimum Level	Maximum Level	Limit	Unit of Measure	Source of Constituent
2003 2003	Bicarbonate	366.000	366	366	NA	ppm	Corrosion of carbonate rocks such as limestone.
2000 2000	Calcium	34.000	34	34	NA	ppm	Abundant naturally occurring element.
2003 2003	Chloride	20.000	20	20	300	ppm	Abundant naturally occurring element; used in water purification; byproduct of oil field activity.
2000 2000	Copper	0.104	0.104	0.104	NA	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
2000 2000	Iron	0.079	0.079	0.079	0.3	ppm	Erosion of natural deposits; iron or steel water delivery equipment or facilities.
2000 2000	Lead	26.200	26.2	26.2	NA	ppb	Corrosion of household plumbing systems; erosion of natural deposits.
2000 2000	Magnesium	19.000	19	19	NA	ppm	Abundant naturally occurring element.
2003 2003	pH	7.500	7.5	7.5	NA	units	Measure of corrosivity of water.
2000 2000	Sodium	86.500	86	87	NA	ppm	Erosion of natural deposits; byproduct of oil field activity.
2003 2003	Sulfate	26.000	26	26	300	ppm	Naturally occurring; common industrial byproduct; byproduct of oil field activity.
2003 2003	Total Alkalinity as CaCO ₃	300.000	300	300	NA	ppm	Naturally occurring soluble mineral salts.
2003 2003	Total Dissolved Solids	361.000	361	361	1000	ppm	Total dissolved mineral constituents in water.
2000 2000	Total Hardness as CaCO ₃	164.000	164	164	NA	ppm	Naturally occurring calcium.